

NOTES


- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
- A FRONT AND REAR ACCESS REQUIRED FOR SERVICE. MINIMUM REQUIRED FRONT CLEARANCE IS 914 [36.0] & REAR CLEARANCE IS 203 [8] .
- 5. NET WEIGHT OF THE UNIT IS 114kg [251.3 lb].
- 6. BOTTOM CABLE ENTRY USING APPROPRIATE CUSTOMER PROVIDED SOLUTION.
- 7. PROTECTION CLASS: IP2X.
- 8. COLOR: MAPLE.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



TITLE: NETSHELTER SOUNDPRO 750mm Wide x 1130m SERVER RACK ENCLO GENERAL ARRANGEM	m Deep SURE
PROJECT: SUBMITTAL DRAWINGS	SHEET 1 OF 3

	DWG NO:	R40	12A	REV.
	DRAWN BY:	ASHISH	31-MAY-23	FIRST
	ENGINEER:	RICHARD PHILLIPS	07-JUN-23	ANGLE
3	APPROVED BY:	JAKE ZIMMER	07-JUN-23	PROJECTION



1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.

3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

4. FRONT DOOR SWING IS 160° AND REAR DOOR SWING IS 120°.


ARACK CAN BE SECURED TO THE FLOOR BY REUSING THE PALLET BRACKETS AND IS OPTIONAL. M8x25 (4 NOS) BLOTS FOR FIXATION ARE NOT PROVIDED & TO BE PROCURED SEPARATELY.


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE



TLE:
NETSHELTER SOUNDPROOF 12U
750mm Wide x 1130mm Deep SERVER RACK ENCLOSURE
SERVER RACK ENCLOSURE '
TOP & BOTTOM VIEWS

DWG NO:	R40	12A	REV.
DRAWN BY:	ASHISH	31-MAY-23	FIRST
ENGINEER:	RICHARD PHILLIPS	07-JUN-23	ANGLE
APPROVED BY:	JAKE ZIMMER	07-JUN-23	PROJECTION





NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.

2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.

3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF TEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.



I TITLE:	
NETSHELTER SOUNDPROOF	12
750mm Wide x 1130mm D	ee
SERVER RACK ENCLOSURE	
INTERNAL & SECTION VIEW	

PROJECT: SUBMITTAL DRAWINGS SHEET 3 OF

	DWG NO:	R40	12A	REV. O
	DRAWN BY:	ASHISH	31-MAY-23	FIRST
	ENGINEER:	RICHARD PHILLIPS	07-JUN-23	ANGLE
3	APPROVED BY:	JAKE ZIMMER	07-JUN-23	PROJECTION