

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product

Uninterruptible power supply with optional battery pack

Name and address of the applicant

APC by Schneider Electric  
Boston ONE Campus, 800 Federal Street, Andover MA  
01810-1067  
UNITED STATES OF AMERICA

Name and address of the manufacturer

APC by Schneider Electric  
Boston ONE Campus, 800 Federal Street, Andover MA  
01810-1067  
UNITED STATES OF AMERICA

Name and address of the factory

AMERICAN POWER CONVERSION CORPORATION  
(A.P.C.) B.V.  
Lot 3, Block 14, Phase III, PEZA, 4106 ROSARIO, CAVITE  
PHILIPPINES

*Note: When more than one factory, please report on page 2*

Additional Information on page 2

Ratings and principal characteristics

Input: 220-240Vac, 50-60Hz, 27A, 1P+N+PE  
Output: 220/230/240Vac, 50/60Hz, 22.8A, 5kVA, 5kW

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF stage 1

Model / Type Ref.

SRTL5KRM2UI, SRTL5KR2I-NB  
SRTL180RM2UBP, SRTL180R2BP-NB

Additional information (if necessary may also be reported on page 2)

(type reference may or may not be followed by suffixes, refer to model matrix in test report for details)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017  
IEC 62040-1:2017/AMD1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

298507-TL4-1

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2022-09-15

Signature:

J. Richter



Ref. Certif. No.

**DE1-66195/M1**

AMERICAN POWER CONVERSION CORPORATION  
(A.P.C.) B.V.  
Lot 10, Block 16, Phase IV, 4106 PEZA, ROSARIO,  
CAVITE  
PHILIPPINES

Danam Philippines, Inc  
Lot 1-A Block 15, Phase III, 4106 PEZA, Rosario,  
Cavite  
PHILIPPINES

International Precision Assemblies, Inc.  
Blk 17, Lot 2 Phase IV, CEPZA Rosario, 4106 Cavite  
PHILIPPINES

**Additional information (if necessary)**

Date of origin: 2022-03-28

Reason for M1: Change of circuit breaker rating

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2022-09-15

Signature:

J. Richter