

**NO  
EXCUSES!**

**SIGNALING**



## FIRE ALARM DOCUMENTS

The FAD is the perfect fit to meet the demanding code requirements today. SAE's number one goal is to manufacture code compliant solutions and this product allows you to do just that. NFPA 72 2007 section 6.2.2.1 states, "A record of installed software and firmware version numbers shall be maintained at the location of the fire alarm control unit."

This durable 16 gauge steel enclosure with a solid piano hinge and key lock will keep all of your code required documents in one safe place. With a 4GB USB flash drive it stores your fire alarm software safe and secure eliminating the occurrences of the software not being on site when technicians arrive to service the system. Along with your fire alarm software you can store your test & inspection documents, service records, manuals & AS built drawings for the system. Using a standard USB B connector it allows you to plug in with any standard SB printer cable to upload or download information.

The FDB is designed to hold critical manuals and documents with a durable steel retainer. It has designated hooks to organize key rings and hold important business cards for easy access and reference. Inside the cover it has a organized note table that allows for documentation for passwords and other critical system information.

### Standard Features:

- Installed with a 4 gig digital flash drive with USB B connector
- 2 Key ring hooks to hold system keys
- Business card holder for key contacts
- Overall Dimensions are 12" x 13" tall and 2 ¼ deep
- 16 gauge steel box and cover for security
- Durable powercoat baked on finish other colors available
- Standard ¾" cat 30 key lock other lock assemblies available
- Solid stainless steel piano hinge
- Permanently screened white ink 1" high "Fire Alarm Documents"
- Legend sheet for passwords and system information



**ISO 9001  
REGISTERED  
COMPANY**

**ACEBOX**

Space Age Electronics, Inc.  
www.1sae.com  
800.486.1723 Toll Free  
508.485.0966 Local  
508.485.4740 Fax

# Specifications:

The fire alarm documents box (FAD) shall be UL Listed, constructed of 18 gauge cold rolled steel. It shall have a red powder coat epoxy finish. The cover shall be permanently screened with 1" high lettering "FIRE ALARM DOCUMENTS" with white indelible ink. The access door shall be locked with a 3/4" barrel lock and the hinge shall be a solid width 12" stainless steel piano hinge. The enclosure will supply 4 mounting holes. Inside the enclosure will accommodate standard 8 1/2 x 11 manuals and loose document records that will be protected within the enclosure. A legend sheet will be permanently attached to the door for system required documentation, key contacts and system information. The FAD will have securely mounted inside a minimum of 4 Gigabyte digital flash memory drive with a standard USB B connector for uploading and downloading information. The drive shall not be accessible without tools to any person whom gains access to the records. The enclosure shall also provide 2 key ring holders with a location to mount standard business type cards for key contact personnel.



USB Storage Interface Requires Standard USB-B Connector

Key Ring Hooks

Business Card Holder

For replacement forms order PIN: EA0316 (Qty. 10)

<b>Property Information</b>	<b>Minimum Required Documentation (SIG-FUN)</b>
Name of property: _____ Address: _____ Description of property: _____ Occupancy type: _____	(Reference NFPA-72 2013 Section 7.2.1) 1 Written narrative providing intent and system description ☐ NA ☐ Enclosed ☐ At Location
<b>Certifications and Approvals</b> <b>16.1 System Installation Contractor:</b> This system, as specified herein, has been installed and tested according to all NFPA standards cited herein.	2 Riser diagram ☐ NA ☐ Enclosed ☐ At Location
Signed: _____ Printed name: _____ Date: ____/____/____ Organization: _____ Title: _____ Phone: _____	3 Floor plan layout showing location of all devices and control equipment ☐ NA ☐ Enclosed ☐ At Location
<b>16.5 Authority Having Jurisdiction:</b> I have witnessed a satisfactory acceptance test of this system and find it to be installed and operating properly in accordance with its approved plans and specifications, with its approved sequence of operations, and with all NFPA standards cited herein.	4 Sequence of operation in either an input/output matrix or narrative form ☐ NA ☐ Enclosed ☐ At Location
Signed: _____ Printed name: _____ Date: ____/____/____ Organization: _____ Title: _____ Phone: _____	5 Equipment technical data sheets ☐ NA ☐ Enclosed ☐ At Location
<b>Equipment Information</b>	6 Manufacturers published instructions, including operation and maintenance instruction ☐ NA ☐ Enclosed ☐ At Location
ID No 1: _____ Serial: _____ Access code: _____	7 Battery calculations (where batteries are provided) ☐ NA ☐ Enclosed ☐ At Location
ID No 2: _____ Serial: _____ Access code: _____	8 Voltage drop calculations for notification appliance circuits ☐ NA ☐ Enclosed ☐ At Location
Signed: _____ Date: ____/____/____	9 Completed record of inspection and testing in accordance with 7.6.6 and 7.8.2 ☐ NA ☐ Enclosed ☐ At Location
Space Age Electronics, Inc. 58 Chocksett Road Sterling, MA 01564 800-486-1723 www.1sae.com LT10644 Rev. 1	10 Completed record of completion in accordance with 7.5.6 and 7.8.2 ☐ NA ☐ Enclosed ☐ At Location
	11 Copy of site specific software, where applicable ☐ NA ☐ Enclosed ☐ At Location
	12 Record (as built) drawings ☐ NA ☐ Enclosed ☐ At Location
	13 Periodic inspection, testing, and maintenance documentation in accordance with Section 7.6 ☐ NA ☐ Enclosed ☐ At Location
	14 Records, record retention, and record maintenance in accordance with 7.7 ☐ NA ☐ Enclosed ☐ At Location

Legend sheet for storing system information including contacts, sign-off, maintenance & test information, and alternate locations of additional records.

## Ordering Information:

**Part # Description**

**SSU00685 Fire Alarm Storage Cabinet RED**

**SSU00686 Custom screening with your Logo**

Check out our Infinity line eFAD single gang 2 Gig digital storage solutions (IAMEFAD)



Space Age Electronics, Inc.  
www.1sae.com  
800.486.1723 Toll Free  
508.485.0966 Local  
508.485.4740 Fax

No Excuses, Just Solutions!

This document is subject to change without notice, see doc # ED0479 for legal disclaimer