WIREMOLD®
Wire Management Systems

4000 Two-Piece Metal Raceway
INSTALLATION INSTRUCTIONS

Wiremold® Electrical Systems conform with, and should be installed and properly grounded in compliance with requirements of the current National Electrical Code or codes administered by local authorities. All electrical products may represent a possible shock or fire hazard if improperly installed or used. Wiremold electrical products are UL Listed, made for interior use and should be installed by qualified electrical professionals in conformance with current local codes and/or the National Electrical Code.


Use #8 (5/16", [7.9mm] head size) flat head fastener or equivalent to mount base to surface.

Utiliser une à tête plate de calibre 8 (tête de 7.9mm, 5/16" po.) ou une fixation équivalente pour assujettir le tube guide-fils et les raccords a la surface de montage.


Use un sujetador de cabeza plana No.8 (tamaño de cabeza: 7.9mm, 5/16" de pulgada) o su equivalente para unir la canalita y los accesorios a la superficie de montaje.

4010DFO FiberReady™ Entrance End Fitting


1




2



3



4



© Copyright 2000 The Wiremold Company All Rights Reserved • 60 Woodlawn Street, West Hartford, CT 06110 • 1-800-621-0049 • Fax 860-232-2062 ***www.wiremold.com*** 41948 1100