

## APC™ Smart-UPS™ Modular Ultra XRCC - XBP Communication Card

### DANGER

#### RISK OF ELECTRIC SHOCK

- Read and follow all safety and installation instructions in the Safety Guide and General Information.
- XRCC should be replaced by service personnel only.
- For UPS installation with SBU, SBU can remain in normal mode; UPS can be in any mode.
- For UPS installation without SBU, UPS can be in any mode.
- Battery Modules in all XBPs must be set OFF; disconnect XBP cable that connects to UPS.

**Failure to follow these instructions will result in equipment damage, personal injury or death.**

