

APC™ Smart-UPS™ Modular Ultra SYCC - UPS Communication Card

DANGER

RISK OF ELECTRIC SHOCK

- Read and follow all safety and installation instructions in the Safety Guide and General Information.
- SYCC should be replaced by service personnel only.
- For UPS installation with SBU, SBU switch must be set to Bypass mode, and lockout and tagout (LOTO) procedures must be followed.
- For UPS installation without SBU, switch off the electrical panel circuit breaker before installing or servicing the unit or connected equipment.
- UPS must be totally de-energized with all battery input power and input AC disconnected.

Failure to follow these instructions will result in equipment damage, personal injury or death.

